

FACILITY	DATE
Sample Airport Building	17/04/2001

**Location:** Window, Drawing Grid Line 6 at R

## INFRARED IMAGE



IR information	Value
Date of creation	17/04/2001
Time of creation	9:31:41 PM
Object parameter	Value
Ambient temperature	1.4°C

## INFORMATION:

Infrared image of a sample building window.  
 Located at drawing grid lines 6 at R. West elevation.  
 Air leakage noted at the top-right corner (at arrow).

**Suspect:** Air leakage at location.

See IR information chart above for maximum temperature inside area box.